

# PV TEST CERTIFICATE

CERTIFICATE:  
ELIOCERT ID20231213

REPORT N°:  
20231010-230055 VOLTEC-RAP ELIOCERT-01

LICENSE HOLDER:

**VOLTEC SOLAR**  
RUE DES PRES, 1  
67190 DINSHEIM-SUR-BRUCHE  
FRANCE

MODULE TYPE/ PRODUCT :

**TARKA 126 VSBD 346,5 to 423,5 Wp\*** (step of 1 Wp)

\* The module references are the TARKA 126 VSBD 385 Wp

The above stated power ranges already consider the 10% margin according to the applicable IEC TS 62915 retesting guide and can not be extended further.

MANUFACTURING PLAN :

**VOLTEC SOLAR**  
RUE DES PRES, 1  
67190 DINSHEIM-SUR-BRUCHE  
FRANCE

TRADEMARK:



BASIS OF QUALIFICATION :

This certificate establishes that all the required tests of the related tests schemes from the standards detailed below were passed according to their regulation of the pass criteria.

**IEC 61215 - Design qualification and type approval of photovoltaic modules ( First edition - 2016-03 )**

- Part 1 : Test requirements
- Part 1-1: Special requirements for testing of crystalline silicon photovoltaic modules
- Part 2: Test procedures

**IEC 61730 - Photovoltaic modules safety qualification ( Second edition - 2016-08 )**

- Part 1: Requirements for construction
- Part 2: Requirements for testing

**IEC TS 62915 - Photovoltaic modules - Type approval, design and safety qualification - Retesting**



ELIOCERT ID20231213

APPLICATION CLASS :	A	SAFETY CLASS:	II
MAXIMUM SYSTEM VOLTAGE :	1500 VDC	HAIL TEST DIAMETER :	25 mm
MAXIMUM PRESSURE / DEPRESSURE :	2400Pa / 2400 Pa	CERTIFICATE VALIDITY PERIOD * :	17/12/2028

\* The certificate validity is linked to a valid Eliosys annual factory inspection certificate for the associated manufacturing plants.

REMARKS:

They may be used in PV plants at a maximum system voltage of up to 1500 VDC.  
The fire test (IEC 61730-2/MST 23) was not performed.

CONDITIONS:

The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type. Further details on certified models in the constructional data form: 20231010-230055 VOLTEC-ENR-App Certif-TARKA 126 VSBD 385

Technical data, materials and components description are into the indicated test report. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

THIS CERTIFICATE IS ISSUED BY ELIOSYS

DATE : 18/12/2023



C.E.O  
JULIEN THIRY